Advanced Fire & Safety, LLC
211 Jared Drive
Broussard, LA 70518
Phone: 337-330-8186 Fax: 337-330-8406

Fire Detection Calibration Report

Customer: Talos Energy Date: 3/24/2017

Location: BM-5 Camp Due Date: 6/24/2017

System Location: Office / Galley System Type: Detcon 410AFP-SS

No.	Sensor Location	Type	Model	Supervised	Test Source	Functions Performed Upon Activation
1	Office / Galley	Pullstation	DI-3	Yes	T	Audible / Shunt Trip
2	Bathroom	Thermal	DT-11	Yes	V	Audible / Shunt Trip
3	A/C Closet	Thermal	9 Volt	Yes	T	Local Audible
4	Bedroom	Smoke	DI-3	No	T	Audible / Shunt Trip
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						

Visuals Tested ? ☐ Yes ☑ No ☐ N/A	Audibles Tested ? ☐ Yes ☑ No ☐ N/A	Shut-In Tested? ☐ Yes ☑ No ☐ N/A
Annual Function Test Date: N/A	Tested in Bypass: ☐ Yes ☑ No	Safe Chart # :
Battery Under One Hour Load Test: 25.3		Safe Chart Date:
T=Test Smoke H=Heat P=Pulled U=UV/IR Light M=Magnet V=Visual S=Self Test		
SYSTEM TAKEN OUT OF BYPASS UPON DEPARTURE	☑ Yes ☐ No	

Comments: All working upon departure from location.

Technician Signature

Customer Representative Signature

Brian Hebert

Customer Representative (Print)

Advanced Fire & Safety, LLC
Phone: 337-330-8186 Fax: 337-330-8406

Gas Detection Calibration Report

Customer: Talos Energy **Date:** 3/24/2017

Location: BM-5 Camp **Due Date:** 6/24/2017

System Location: Office / Galley **System Type:** Detcon 410-AFP-SS

NO.	Sensor Location	Detector Model	Alm. Set Points		Zero		Span		Max	Functions Performed Upon Activation			
			Low	High	Found	Left	Found	Left	Span	Low Alarm	Verified	High Alarm	Verified
1	Office / Galley	FP-424C	20	50	0	0	47	50	100	Audible	No	Shunt Trip Power	No
2	Bedroom	FP-424C	20	50	0	0	48	50	100	Audible	No	Shunt Trip Power	No
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

Battery Voltage Under One Hour Load Test: 25.3 **Battery Quanity:** 4 **Amp Hour Rating:** 7AH

Safe Chart #: **Safe Chart Date:** **Cal Gas Exp. Date:** 2/1/2021

Last Annual Function Test Date: **Tested in Bypass:** ☑ Yes ☐ No **Cal Gas Lot #:** TBBH-135A-2.5-15

SYSTEM TAKEN OUT OF BYPASS UPON DEPARTURE ☑ Yes ☐ No

Comments: The gas card for the bedroom is not working and recommend changing it out, it doesn't read gas or alarm.

Lead Technician Signature

Customer Representative Signature

Brian Hebert

Customer Representative (Print)

Advanced Fire & Safety, LLC

211 Jared Drive
Broussard, LA 70518
Phone: 337-330-8186 Fax: 337-330-8406

Certificate Of Inspection

Customer: Talos Energy **Date:** 3/24/2017

Location: BM-5 Camp **Job.#:** 17-1120

Type Of Inspection: ____ Monthly __X__ Quarterly ____ Semi Annual ____ Annual ____ Service Call
____ Other _____

Station Bill Drawings Available? __X__ Yes ____ No

All Equipment Locations Been Verified As Per The Platform Station Bill? __X__ Yes ____ No

Station Bill Date: _____ Station Bill # : N/A

Safe Chart Date: _____ Safe Chart #: N/A

Comments: **Fire & gas Detection**

WORK PERFORMED ON

Fire Fighting Equipment
- ____ Hand Portable
- ____ Semi Portable
- ____ Other _____
- ____ Other _____

Fire Detection System
- __X__ Smoke / P.O.C
- __X__ Thermal
- ____ U / V
- ____ Other _____

Safety Equipment & Warning Devices
- ____ Life Saving Equipment
- ____ Swing Ropes / Escape Ropes
- ____ General Alarm / Paging System
- ____ Third Party USCG Inspection
- ____ Aids To Navigation
- ____ Other _____
- ____ Other _____

Fire Fighting System
- ____ CO2
- ____ Halon
- ____ DC
- ____ Foam
- ____ Water
- ____ FM-200
- ____ Fire Hose Reels

GAS DETECTION SYSTEM
- __X__ COMB (LEL)
- ____ TOXIC (H2s-CO-ETC.)
- ____ Oxygen
- ____ Combination
- _____

INSPECTION REPORT ATTACHED FOR DETAIL

__X__ YES ____ NO

This is to certify that the equipment described herein has been inspected and/or tested as required in accordance with applicable code and mfg. recommendation.

____ YES __X__ No

This is to certify that the equipment described herein is left in 100% proper working condition as of this certificate date.

Lead Technician

Customer Representative

3/24/2017
Date

Brian Hebert
Customer Representative (Print)

Advanced Fire & Safety, LLC

211 Jared Drive
Broussard, LA 70518
Phone: 337-330-8186 Fax: 337-330-8406

SUGGESTIONS / DEFICIENCIES

Customer: Talos Energy **Date:** 3/24/2017

Location BM-5 Camp **Job#:** 17-1120

Customer P.O.#:

No.	Location	Comments
	Bedroom	The gas card for the bedroom gad head is not reading the gas or going into alarm and recommend changing it out

AS per the PIC, Advanced will correct the above deficiencies. X Yes ___ No

As per the PIC, the customer will correct the above deficiencies. ___ Yes X No

Brian Hebert
Customer Representative Signature

3/24/2017
Date

Technician Signature

Brian Hebert
Customer Representative (Print)

ADVANCED FIRE & SAFETY, LLC

Advanced Fire & Safety, LLC
211 Jared Drive
Broussard, LA 70518
337-330-8186 / 337-330-8406

Ticket No.
Job No. 17-1120
Job Complete? [X] YES [ ] NO

CUSTOMER	*Talos Energy*	**LEASE:**	
ADDRESS		**WELL:**	
CITY, STATE		**FIELD:**	*BM-Camp*
		PO# :	
Scope of Job:		**AFE #:**	

DATE	EMPLOYEE NAME	START	STOP	HOURS	CLASSIFICATION	RATE	AMOUNT
3/24/17	*C Wehner*	*0600*	*0800*	*2*	*Technician*	$ *52.00*	$ *104.00*
					Technician	$ *52.00*	$ -
						$ *52.00*	$ -
						$ *52.00*	$ -
						$ *52.00*	$ -
						$ *52.00*	$ -
						$ *52.00*	$ -
						Total Labor	$ *104.00*

WORK DESCRIPTION / MATERIAL, EQUIPMENT USED / COMMENTS / PRICES

Went over to location to do the annual inspection on the fire fighting & life saving equipment and the fire & gas detection

Quantity	Parts Used:	Price Each	Total
7	*Tyrap.Seal & Tag*	$ 3.00	$ 21.00
2	*Per Point of calibration gas*	$ 3.00	$ 6.00
2	*Per Point of test smoke for smoke detector*	$ 1.00	$ 2.00
			$ -
		$ -	$ -
		$ -	$ -
		Total	$ 29.00

Mileage: 20 **Destination Traveled:** Fourchon,La. **Mileage billable?** [X] YES [ ] NO

Mileage Rate $ 1.00

Labor subtotal	$ 104.00
Mileage	$ 20.00
Parts	$ 29.00
Applicable tax	$ -
Grand Total	$ **153.00**

EMPLOYEE SIGNATURE:	**CUSTOMER SIGNATURE:**
EMPLOYEE PRINT NAME: *Chris Wehner*	**CUSTOMER PRINT NAME:** *Brian Hebert*
Total Hours: **Regular** **Overtime**	**CUSTOMER PHONE #**

SML7 revision 09.09